



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

**Pattengill Elementary School**

**Date of Sampling: January 5, 2023**

**Sampler: Victoria Heed**

Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Pattengill-09	Room A-7, Combination Sink, Glass Filler	C	10:50 AM	5	ND <sup>3</sup>	N	Y	7/7/2022	Initial First Draw, Filtered.
Pattengill-19	Room C-4, Combination Sink, Glass Filler	C	10:05 AM	5	ND	N	Y	7/11/2022	Initial First Draw, Filtered.
Pattengill-22	Room B-3, Combination Sink, Glass Filler	C	10:11 AM	5	ND	N	Y	7/8/2022	Initial First Draw, Filtered.
Pattengill-24	Room B-4, Combination Sink, Glass Filler	C	10:15 AM	5	ND	N	Y	7/8/2022	Initial First Draw, Filtered.
Pattengill-31	Room B-8, Combination Sink, Glass Filler	C	10:26 AM	5	ND	N	Y	7/7/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Pattengill Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Pattengill-39	Room B-16, Combination Sink, Glass Filler	C	10:21 AM	5	ND	N	Y	7/7/2022	Initial First Draw, Filtered.
Pattengill-44	Room A-2, Combination Sink, Glass Filler	C	10:43 AM	5	ND	N	Y	7/8/2022	Initial First Draw, Filtered.
Pattengill-52	Room A-9, Combination Sink, Glass Filler	C	10:38 AM	5	ND	N	Y	7/8/2022	Initial First Draw, Filtered.
Pattengill-55	Hallway, Outside Room A-7, Hydration Station, Bottle Fill	HS	10:47 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Pattengill-58	Cafeteria Kitchen, Right Single Combination Sink, Glass Filler	C	10:00 AM	5	ND	N	Y	7/11/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L