



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Angell Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Angell-03	Nurse Clinic, Combination Sink, Glass Filler	C	7:42 AM	5	ND ³	N	Y	6/26/22	Initial First Draw, Filtered.
Angell-07	Room C-119, Combination Sink, Glass Filler	C	7:53 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Angell-10	Room C-207, Combination Sink, Glass Filler	C	7:58 AM	5	ND	N	Y	6/14/22	Initial First Draw, Filtered.
Angell-15	Room C-121, Combination Sink, Glass Filler	C	7:49 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Angell-19	Room C-110, Combination Sink, Glass Filler	C	7:45 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Angell Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Angell-26	Hallway, Outside Main Office, Hydration Station, Bottle Fill	HS	7:39 AM	5	ND	Y	Y	Unknown	Initial First Draw, Filtered.
Angell-35	Room C-213, Combination Sink, Glass Filler	C	8:01 AM	5	ND	N	Y	6/14/22	Initial First Draw, Filtered.
Angell-41	Cafeteria, Hydration Station, Bottle Fill	HS	7:36 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L