



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

STEAM at Northside							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 01	Room 101, Bubbler	B	8:41 AM	5	ND ³	N	First Draw, Filtered.
STEAM - 02	Room 104, Bubbler	B	9:01 AM	5	ND	N	First Draw, Filtered.
STEAM - 03	Staff Lounge, Single Sink, Faucet	F	9:25 AM	5	ND	Y	First Draw, Filtered.
STEAM - 04	Room 503, Bubbler	B	9:31 AM	5	ND	N	First Draw, Filtered.
STEAM - 05	Room 401, Bubbler	B	9:50 AM	5	ND	N	First Draw, Filtered.
STEAM - 06	Room 501, Bubbler	B	9:44 AM	5	ND	N	First Draw, Filtered.
STEAM - 07	Gym, Single Bottle Fill	BT	10:08 AM	5	ND	N	First Draw, Filtered.
STEAM - 08	Hallway, Outside Gym Left Bubbler	B	10:00 AM	5	ND	N	First Draw, Filtered.
STEAM - 09	Hallway, Outside Kitchen, Hydration Station, Water Cooler	BT	10:55 AM	5	ND	N	First Draw, Filtered.
STEAM - 10	Room MS-3, In Closet, Single Sink, Faucet	F	10:29 AM	5	ND	Y	First Draw, Filtered.
STEAM - 11	Room MS-2, In Closet, Single Sink, Faucet	F	10:35 AM	5	1	Y	First Draw, Filtered.
STEAM - 12	Hallway, Outside MS-1, Left Water Cooler	WC	10:17 AM	5	ND	N	First Draw, Filtered.
STEAM - 13	Room K-3, Combination Sink, Bubbler	C	9:05 AM	5	ND	N	First Draw, Filtered.
STEAM - 14	Room K-3, Combination Sink, Faucet	C	9:06 AM	5	ND	Y	First Draw, Filtered.
STEAM - 15	Room 104, Combination Sink, Faucet	C	9:03 AM	5	2	Y	First Draw, Filtered.
STEAM - 16	Room 103, Combination Sink, Bubbler	C	8:51 AM	5	ND	N	First Draw, Filtered.
STEAM - 17	Room 103, Combination Sink, Faucet	C	8:52 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

STEAM at Northside							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 18	Room 102, Combination Sink, Bubbler	C	8:46 AM	5	ND	N	First Draw, Filtered.
STEAM - 19	Room 102, Combination Sink, Faucet	C	8:47 AM	5	ND	Y	First Draw, Filtered.
STEAM - 20	Room 101, Combination Sink, Faucet	C	8:43 AM	5	ND	Y	First Draw, Filtered.
STEAM - 21	Room K-2, Combination Sink, Bubbler	C	8:32 AM	5	ND	N	First Draw, Filtered.
STEAM - 22	Room K-2, Combination Sink, Faucet	C	8:33 AM	5	ND	Y	First Draw, Filtered.
STEAM - 23	Room K-1, Combination Sink, Bubbler	C	8:26 AM	5	ND	N	First Draw, Filtered.
STEAM - 24	Room K-1, Combination Sink, Faucet	C	8:27 AM	5	ND	Y	First Draw, Filtered.
STEAM - 25	Room MS-5, In Closet, Single Sink, Faucet	F	10:33 AM	5	22	Y	First Draw, Filtered.
STEAM - 26	Room MS-1, In Closet, Single Sink, Faucet	F	10:26 AM	5	27	Y	First Draw, Filtered.
STEAM - 27	Nurse's Clinic, Single Sink, Faucet	F	12:08 PM	5	3	Y	First Draw, Filtered.
STEAM - 28	Hallway, Outside Teachers Lounge, Hydration Station, Water Cooler	BT	9:19 AM	5	ND	N	First Draw, Filtered.
STEAM - 29	Hallway, Outside Teachers Lounge, Left Water Cooler	WC	9:17 AM	5	ND	N	First Draw, Filtered.
STEAM - 30	Room 503, Combination Sink, Faucet	C	9:32 AM	5	ND	Y	First Draw, Filtered.
STEAM - 31	Room 502, Combination Sink, Bubbler	C	9:36 AM	5	ND	N	First Draw, Filtered.
STEAM - 32	Room 502, Combination Sink, Faucet	C	9:37 AM	5	1	Y	First Draw, Filtered.
STEAM - 33	Room 501, Combination Sink, Faucet	C	9:46 AM	5	ND	Y	First Draw, Filtered.
STEAM - 34	Room 403, Combination Sink, Bubbler	C	9:40 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

STEAM at Northside							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 35	Room 403, Combination Sink, Faucet	C	9:41 AM	5	ND	Y	First Draw, Filtered.
STEAM - 36	Room 401, Combination Sink, Faucet	C	9:51 AM	5	ND	Y	First Draw, Filtered.
STEAM - 37	Room 402, Combination Sink, Bubbler	C	9:55 AM	5	ND	N	First Draw, Filtered.
STEAM - 38	Room 402, Combination Sink, Faucet	C	9:56 AM	5	ND	Y	First Draw, Filtered.
STEAM - 39	Hallway, Outside Gym, Right Bubbler	B	10:01 AM	5	ND	N	First Draw, Filtered.
STEAM - 40	Gym, Right Bubbler	B	10:07 AM	5	1	N	First Draw, Filtered.
STEAM - 41	Media Center, Single Sink, Faucet	F	10:50 AM	5	1	Y	First Draw, Filtered.
STEAM - 42	Hallway, Outside Kitchen, Hydration Station, Bottle Fill	BT	10:56 AM	5	ND	N	First Draw, Filtered.
STEAM - 43	Kitchen 3-Compartment Sink, Add On Faucet, Far Right	KF	11:00 AM	5	1	Y	First Draw, Filtered.
STEAM - 44	OPEN NUMBER						
STEAM - 45	Room 303, Combination Sink, Faucet	C	11:15 AM	5	2	Y	First Draw, Filtered.
STEAM - 46	Room 303, Combination Sink, Bubbler	C	11:17 AM	5	ND	N	First Draw, Filtered.
STEAM - 47	Room 302, Combination Sink, Faucet	C	11:21 AM	5	ND	Y	First Draw, Filtered.
STEAM - 48	Room 303, Combination Sink, Bubbler	C	11:22 AM	5	ND	Y	First Draw, Filtered.
STEAM - 49	Room 301, Combination Sink, Faucet	C	11:54 AM	5	1	N	First Draw, Filtered.
STEAM - 50	Room 301, Combination Sink, Bubbler	C	11:55 AM	5	ND	N	First Draw, Filtered.
STEAM - 51	Room 203, Combination Sink, Faucet	C	11:50 AM	5	2	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

STEAM at Northside							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 52	Room 203, Combination Sink, Bubbler	C	11:51 AM	5	ND	N	First Draw, Filtered.
STEAM - 53	Room 202, Combination Sink, Faucet	C	11:45 AM	5	ND	Y	First Draw, Filtered.
STEAM - 54	Room 202, Combination Sink, Bubbler	C	11:46 AM	5	ND	N	First Draw, Filtered.
STEAM - 55	Room 201, Combination Sink, Faucet	C	11:41 AM	5	ND	Y	First Draw, Filtered.
STEAM - 56	Room 201, Combination Sink, Bubbler	C	11:43 AM	5	ND	N	First Draw, Filtered.
STEAM - 57	Hallway, Outside MS-6, Hydration Station, Bottle Fill	BT	10:40 AM	5	ND	N	First Draw, Filtered.
STEAM - 58	Hallway, Outside MS-6, Hydration Station Water Cooler	BT	10:42 AM	5	ND	N	First Draw, Filtered.
STEAM - 59	Hallway, Outside MS-1, Hydration Station, Water Cooler	BT	10:20 AM	5	ND	N	First Draw, Filtered.
STEAM - 60	Hallway, Outside Room 200, Hydration Station, Water Cooler	BT	11:34 AM	5	ND	N	First Draw, Filtered.
STEAM - 61	Hallway, Outside Room 200, Hydration Station, Bottle Fill	BT	11:36 AM	5	ND	N	First Draw, Filtered.
STEAM - 62	Multi-Purpose Room, Hydration Station, Water Cooler	BT	11:05 AM	5	ND	N	First Draw, Filtered.
STEAM - 63	Multi-Purpose Room, Hydration Station, Bottle Fill	BT	11:03 AM	5	ND	N	First Draw, Filtered.
STEAM - 64	Hallway, Outside Room 103, Hydration Station, Water Cooler	BT	8:57 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

STEAM at Northside							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 65	Hallway, Outside Room 103, Hydration Station, Bottle Fill	BT	8:56 AM	5	ND	N	First Draw, Filtered.
STEAM - 66	Hallway, Outside Teachers Lounge, Hydration Station, Bottle Fill	BT	9:20 AM	5	ND	N	First Draw, Filtered.
STEAM - 67	OPEN NUMBER						
STEAM - 68	Hallway, Outside MS-1, Hydration Station, Bottle Fill	BT	10:21 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

STEAM at Northside							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 25A	Room MS-5, In Closet, Single Sink, Faucet	F	11:27 AM	5	ND ³	Y	Repeat First Draw, Filtered.
STEAM - 26A	Room MS-1, In Closet, Single Sink, Faucet	F	11:22 AM	5	ND	Y	Follow up Flush, Filtered.

STEAM at Northside							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 25B	Room MS-5, In Closet, Single Sink, Faucet	F	2:56 PM	5	ND	Y	Follow up First Draw Following Replacement, Filtered.
STEAM - 26B	Room MS-1, In Closet, Single Sink, Faucet	F	2:50 PM	5	ND	Y	Follow up First Draw Following Replacement, Filtered.

1) Type: B = Bubble, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested