



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Pathways to Success Academic Campus							
Date of Sampling: 2/22/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-01	Room 113, Left Faucet	F	4:00 PM	5	ND ³	Y	First Draw, Filtered.
Pathways-02	Room 112, Kitchen Faucet	F	3:50 PM	5	14	Y	First Draw, Filtered.
Pathways-03	OPEN NUMBER			5			
Pathways-04	Hallway, Outside Room 402, Hydration Station, Water Cooler	BT	4:35 PM	5	ND	N	First Draw, Filtered.
Pathways-05	Hallway, Outside Room 208, Hydration Station, Bottle Fill	BT	4:20 PM	5	ND	N	First Draw, Filtered.
Pathways-06	Hallway, Outside Room 200, Bubbler	B	3:45 PM	5	ND	N	First Draw, Filtered.
Pathways-07	Hallway, Between Men's and Women's Bathrooms, 300 Hall, Bubbler	B	3:40 PM	5	ND	N	First Draw, Filtered.
Pathways-08	Hallway, Outside Room 308, Hydration Station, Bottle Fill	BT	3:30 PM	5	ND	N	First Draw, Filtered.
Pathways-09	Staff Lounge, 2-Compartment Sink, Faucet	F	4:40 PM	5	ND	Y	First Draw, Filtered.
Pathways-10	Media Center, Staff Workroom, Faucet	F	4:25 PM	5	ND	Y	First Draw, Filtered.
Pathways-11	Kitchen, 3-Compartment Sink, Single Add on Faucet, Far Right	KF	4:45 PM	5	ND	Y	First Draw, Filtered.
Pathways-12	Hallway, Outside Gym, Hydration Station, Water Cooler	BT	4:05 PM	5	ND	N	First Draw, Filtered.
Pathways-13	Hallway, Outside Gym, Single Water Cooler	WC	4:05 PM	5	ND	N	First Draw, Filtered.
Pathways-14	Room 113, Right Faucet	F	4:00 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Pathways to Success Academic Campus							
Date of Sampling: 2/22/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-15	Multi-Purpose Room, Water Cooler	WC	4:45 PM	5	ND	N	First Draw, Filtered.
Pathways-16	Hallway, Outside Room 208, Hydration Station, Water Cooler	BT	4:20 PM	5	ND	N	First Draw, Filtered.
Pathways-17	Hallway, Outside Room 308, Hydration Station, Water Cooler	BT	3:30 PM	5	ND	N	First Draw, Filtered.
Pathways-18	Hallway, Outside Room 402, Hydration Station, Bottle Fill	BT	4:35 PM	5	1	N	First Draw, Filtered.
Pathways-19	Hallway, Outside Gym, Hydration Station, Bottle Fill	BT	4:05 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Pathways to Success Academic Campus							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-02A	Room 112, Kitchen Faucet	KF	12:16 PM	5	18	Y	Repeat First Draw, Filtered.

Pathways to Success Academic Campus							
Date of Sampling: 3/10/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-02B	Room 112, Kitchen Faucet	KF	8:05 AM	5	4	Y	Follow-up First Draw Following Replacement.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested