



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Angell Elementary School									
Type of Sampling: Initial First Draw Sampling (IFD)									
Date of Sampling: February 3, 2024									
Sampler: Zac Fortin									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Angell-05	Kitchen, 3-Compartment Sink, Add On Faucet, Far Right	Kitchen Faucet	8:35 AM	5	ND	Y	Y	6/15/2023	
Angell-08	Room C-221, Combination Sink, Glass Filler	Combination Sink	9:03 AM	5	ND	Y	Y	N/A	
Angell-11	Room C-212, Combination Sink, Glass Filler	Combination Sink	9:15 AM	5	ND	Y	Y	6/15/2023	
Angell-21	Room C-113, Combination Sink, Glass Filler	Combination Sink	8:50 AM	5	ND	Y	Y	6/15/2023	
Angell-28	Room C-209, Combination Sink, Glass Filler	Combination Sink	9:10 AM	5	ND	Y	Y	6/15/2023	
Angell-38	Staff Lounge, Combination Sink, Faucet	Kitchen Faucet	8:40 AM	5	ND	Y	Y	6/15/2023	
Angell-43	Hallway, Outside Room C-110, Hydration Station, Bottle Fill	Hydration Station	8:45 AM	5	ND	Y	Y	N/A	
Angell-45	Hallway, Floor 2, Outside Room C-228, Hydration Station, Bottle Fill	Hydration Station	8:56 AM	5	ND	Y	Y	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L