



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

| Site: Burns Park Elementary School | | | | | | | | | |
|--------------------------------------------------|------------------------------------------------------------------------|--------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|-------|
| Sampling Type: Initial First Draw Sampling (IFD) | | | | | | | | | |
| Date of Sampling: February 3, 2024 | | | | | | | | | |
| Sampler: Zac Fortin | | | | | | | | | |
| Sample # | Location | Fixture Type | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes |
| Burns-03 | Hallway, Outside Kitchen, Hydration Station, Bottle Fill | Hydration Station | 10:15 AM | 5 | ND | Y | Y | N/A | |
| Burns-08 | Hallway, Outside Room 308, Porcelain, Glass Filler | Single Bottle Fill | 10:41 AM | 5 | ND | Y | N | N/A | |
| Burns-12 | Room A-7, Combination Sink, Glass Filler | Combination Sink | 10:33 AM | 5 | ND | Y | Y | 6/20/2023 | |
| Burns-19 | Room A-1, Combination Sink, Glass Filler | Combination Sink | 10:25 AM | 5 | ND | Y | N/A | N/A | |
| Burns-25 | Kitchen, 3-Compartment, Add On Faucet, Far Left Faucet, Kitchen Faucet | Kitchen Faucet | 10:20 AM | 5 | ND | Y | Y | 6/20/2023 | |
| Burns-33 | Portable, Right Refridgerated Glass Filler | Water Cooler | 10:55 AM | 5 | ND | Y | N/A | N/A | |
| Burns-47 | Portable, Hydration Station, Bottle Fill | Hydration Station | 11:00 AM | 5 | ND | Y | N/A | N/A | |

*ND = Non-Detected at Reported Detection Limit of 1 ug/L