



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Ann Arbor STEAM at Northside									
Date of Sampling: January 3, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
STEAM - 02	Room 104, Combination Sink, Glass Filler	C	12:20 PM	5	ND ³	N	Y	6/30/22	Initial First Draw, Filtered.
STEAM - 16	Room 103, Combination Sink, Glass Filler	C	12:17 PM	5	ND	N	Y	6/30/22	Initial First Draw, Filtered.
STEAM - 21	Room K-2, Combination Sink, Glass Filler	C	12:24 PM	5	ND	N	Y	6/30/22	Initial First Draw, Filtered.
STEAM - 34	Room 403, Combination Sink, Glass Filler	C	12:41 PM	5	ND	N	Y	7/1/22	Initial First Draw, Filtered.
STEAM - 39	Hallway, Outside Gym, Hydration Station, Bottle Fill	HS	12:44 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Ann Arbor STEAM at Northside									
Date of Sampling: January 3, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
STEAM - 48	Room 303, Combination Sink, Glass Filler	C	12:51 PM	5	ND	N	Y	6/30/22	Initial First Draw, Filtered.
STEAM - 54	Room 202, Combination Sink, Glass Filler	C	12:55 PM	5	ND	N	Y	6/30/22	Initial First Draw, Filtered.
STEAM - 63	Multi-Purpose Room, Hydration Station, Bottle Fill	HS	12:48 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
STEAM - 67	Staff Lounge, Combination Sink, Glass Filler	C	12:35 PM	5	ND	N	Y	No Date	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L