



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-01	Hallway, Outside Multi-Purpose Room, Left of Girl's Bathroom, Hydration Station, Water Cooler	BT	12:00 PM	5	ND ³	N	First Draw, Filtered.
Mitchell-02	Room 3, Combination Sink, Bubbler	C	2:20 PM	5	ND	N	First Draw, Filtered.
Mitchell-03	Room 3, Combination Sink, Faucet	C	2:20 PM	5	ND	Y	First Draw, Filtered.
Mitchell-04	Room 4, Combination Sink, Bubbler	C	2:25 PM	5	ND	N	First Draw, Filtered.
Mitchell-05	Hallway, New Addition, Right Water Cooler	WC	2:40 PM	5	ND	N	First Draw, Filtered.
Mitchell-06	Room 8, Combination Sink, Bubbler	C	1:15 PM	5	ND	N	First Draw, Filtered.
Mitchell-07	Room 9, Combination Sink, Right Faucet	C	1:05 PM	5	ND	Y	First Draw, Filtered.
Mitchell-08	Teacher's Lounge Faucet	F	12:30 PM	5	ND	Y	First Draw, Filtered.
Mitchell-09	Hallway Outside Gym, Bottle Fill, Water Cooler	BT	12:35 PM	5	ND	N	First Draw, Filtered.
Mitchell-10	Room 15, Single Bubbler	B	12:45 PM	5	ND	N	First Draw, Filtered.
Mitchell-11	Room 19, Single Bubbler	B	12:15 PM	5	ND	N	First Draw, Filtered.
Mitchell-12	Hallway, New Addition, Left Single Bottle Fill	BT	2:45 PM	5	ND	Y	First Draw, Filtered.
Mitchell-13	Room 4, Combination Sink, Faucet	C	2:25 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-14	Hallway, Outside Multi-Purpose Room, Left of Girl's Bathroom, Hydration Station, Bottle Fill	BT	12:00 PM	5	ND	Y	First Draw, Filtered.
Mitchell-15	Room 8, Combination Sink, Faucet	C	1:15 PM	5	ND	Y	First Draw, Filtered.
Mitchell-16	Room 9, Combination Sink, Right Sink, Bubbler	C	1:05 PM	5	ND	N	First Draw, Filtered.
Mitchell-17	Hallway, Outside Gym, Hydration Station, Bottle Fill	BT	12:35 PM	5	ND	Y	First Draw, Filtered.
Mitchell-18	Room 5, Combination Sink, Bubbler	C	1:40 PM	5	ND	N	First Draw, Filtered.
Mitchell-19	Room 5, Combination Sink, Faucet	C	1:40 PM	5	ND	Y	First Draw, Filtered.
Mitchell-20	Room 2, Combination Sink, Right Sink, Bubbler	C	2:10 PM	5	ND	N	First Draw, Filtered.
Mitchell-21	Room 2, Combination Sink, Right Sink, Faucet	C	2:10 PM	5	ND	Y	First Draw, Filtered.
Mitchell-22	Room 2, Combination Sink, Middle Sink, Bubbler	C	2:10 PM	5	ND	N	First Draw, Filtered.
Mitchell-23	Room 2, Combination Sink, Middle Sink, Faucet	C	2:12 PM	5	ND	Y	First Draw, Filtered.
Mitchell-24	Room 2, Combination Sink, Left Sink, Faucet	C	2:12 PM	5	ND	Y	First Draw, Filtered.
Mitchell-25	Room 2, Combination Sink, Left Sink, Bubbler	C	2:12 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-26	Room 1, Combination Sink, Right Sink, Bubbler	C	2:02 PM	5	ND	N	First Draw, Filtered.
Mitchell-27	Room 1, Combination Sink, Right Sink, Faucet	C	2:02 PM	5	ND	Y	First Draw, Filtered.
Mitchell-28	Room 1, Combination Sink, Middle Sink, Faucet	C	2:05 PM	5	ND	Y	First Draw, Filtered.
Mitchell-29	Room 1, Combination Sink, Middle Sink, Bubbler	C	2:05 PM	5	ND	N	First Draw, Filtered.
Mitchell-30	Room 1, Combination Sink, Left Sink, Faucet	C	2:05 PM	5	ND	Y	First Draw, Filtered.
Mitchell-31	Room 1, Combination Sink, Left Sink, Bubbler	C	2:05 PM	5	ND	N	First Draw, Filtered.
Mitchell-32	Room 6, Combination Sink, Right Sink, Bubbler	C	1:45 PM	5	ND	N	First Draw, Filtered.
Mitchell-33	Room 6, Combination Sink, Right Sink, Faucet	C	1:45 PM	5	ND	Y	First Draw, Filtered.
Mitchell-34	Room 6, Combination Sink, Middle Sink, Faucet	C	1:46 PM	5	ND	Y	First Draw, Filtered.
Mitchell-35	Room 6, Combination Sink, Middle Sink, Bubbler	C	1:46 PM	5	ND	N	First Draw, Filtered.
Mitchell-36	Room 6, Combination Sink, Left Sink, Bubbler	C	1:47 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-37	Room 6, Combination Sink, Left Sink, Faucet	C	1:47 PM	5	ND	Y	First Draw, Filtered.
Mitchell-38	Room 9, Combination Sink, Left Sink, Bubbler	C	1:10 PM	5	ND	N	First Draw, Filtered.
Mitchell-39	Room 9, Combination Sink, Left Sink, Faucet	C	1:10 PM	5	ND	Y	First Draw, Filtered.
Mitchell-40	Room 10, Combination Sink, Right Sink, Bubbler	C	1:00 PM	5	ND	N	First Draw, Filtered.
Mitchell-41	Room 10, Combination Sink, Right Sink, Faucet	C	1:00 PM	5	ND	Y	First Draw, Filtered.
Mitchell-42	Room 10 Combination Sink, Left Sink, Faucet	C	1:00 PM	5	ND	Y	First Draw, Filtered.
Mitchell-43	Room 10, Combination Sink, Left Sink, Bubbler	C	1:00 PM	5	ND	N	First Draw, Filtered.
Mitchell-44	Room 14, Combination Sink, Bubbler	C	12:40 PM	5	ND	N	First Draw, Filtered.
Mitchell-45	Room 14, Combination Sink, Faucet	C	12:40 PM	5	ND	Y	First Draw, Filtered.
Mitchell-46	Room 14, Single Bubbler	B	12:42 PM	5	ND	N	First Draw, Filtered.
Mitchell-47	Room 15, Combination Sink, Bubbler	C	12:48 PM	5	ND	N	First Draw, Filtered.
Mitchell-48	Room 15, Combination Sink, Faucet	C	12:48 PM	5	ND	Y	First Draw, Filtered.
Mitchell-49	Room 16, Combination Sink, Bubbler	C	12:55 PM	5	ND	N	First Draw, Filtered.
Mitchell-50	Room 16, Combination Sink, Faucet	C	12:55 PM	5	ND	Y	First Draw, Filtered.
Mitchell-51	Room 16, Single Bubbler	B	12:53 PM	5	2	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-52	Room 20, Combination Sink, Bubbler	C	12:20 PM	5	ND	N	First Draw, Filtered.
Mitchell-53	Room 20, Combination Sink, Faucet	C	12:20 PM	5	ND	Y	First Draw, Filtered.
Mitchell-54	Room 20, Single Bubbler	B	12:21 PM	5	ND	N	First Draw, Filtered.
Mitchell-55	Room 19, Combination Sink, Bubbler	C	12:17 PM	5	ND	N	First Draw, Filtered.
Mitchell-56	Room 19, Combination Sink, Faucet	C	12:17 PM	5	ND	Y	First Draw, Filtered.
Mitchell-57	Kitchen, 3-Compartment Sink, Far Left, Faucet	KF	12:10 PM	5	ND	Y	First Draw, Filtered.
Mitchell-58	Room 7, Community Center, Combination Sink, Bubbler	C	1:20 PM	5	ND	N	First Draw, Filtered.
Mitchell-59	Hallway Outside Room 6, Single Water Cooler	WC	12:00 PM	5	ND	N	First Draw, Filtered.
Mitchell-60	Multi-Purpose Room, Right Water Cooler	WC	12:03 PM	5	ND	N	First Draw, Filtered.
Mitchell-61	Multi-Purpose Room, Hydration Station, Water Cooler	BT	12:05 PM	5	ND	N	First Draw, Filtered.
Mitchell-62	Room 25, Combination Sink, Faucet	C	2:55 PM	5	3	Y	First Draw, Filtered.
Mitchell-63	Room 25, Combination Sink, Bubbler	C	2:55 PM	5	ND	N	First Draw, Filtered.
Mitchell-64	Room 26, Combination Sink, Faucet	C	3:00 PM	5	ND	Y	First Draw, Filtered.
Mitchell-65	Room 26, Combination Sink, Bubbler	C	3:00 PM	5	ND	N	First Draw, Filtered.
Mitchell-66	Room 22, Combination Sink, Bubbler	C	3:05 PM	5	ND	N	First Draw, Filtered.
Mitchell-67	Room 22, Combination Sink, Faucet	C	3:05 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Mitchell Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-68	Room 23, Combination Sink, Bubbler	C	3:10 PM	5	ND	N	First Draw, Filtered.
Mitchell-69	Room 23, Combination Sink, Faucet	C	3:10 PM	5	ND	Y	First Draw, Filtered.
Mitchell-70	Room 24, Combination Sink, Bubbler	C	3:15 PM	5	ND	N	First Draw, Filtered.
Mitchell-71	Room 24, Combination Sink, Faucet	C	3:15 PM	5	ND	Y	First Draw, Filtered.
Mitchell-72	Room 21, Combination Sink, Faucet	C	2:50 PM	5	ND	Y	First Draw, Filtered.
Mitchell-73	Room 21, Combination Sink, Bubbler	C	2:50 PM	5	ND	N	First Draw, Filtered.
Mitchell-74	Portable, Hallway, Right Water Cooler	WC	3:30 PM	5	ND	N	First Draw, Filtered.
Mitchell-75	Portable, Hallway, Hydration Station, Water Cooler	BT	3:35 PM	5	ND	N	First Draw, Filtered.
Mitchell-76	Portable, Hallway, Hydration Station, Bottle Fill	BT	3:35 PM	5	ND	Y	First Draw, Filtered.
Mitchell-77	Hallway, Outside Art Room, Hydration Station, Water Cooler	BT	12:55 PM	5	ND	N	First Draw, Filtered.
Mitchell-78	Hallway, Outside Art Room, Hydration Station, Bottle Fill	BT	12:55 PM	5	ND	Y	First Draw, Filtered.
Mitchell-79	Multi-Purpose Room, Hydration Station, Bottle Fill	BT	12:05 PM	5	ND	Y	First Draw, Filtered.
Mitchell-80	Room 7, Community Center, Combination Sink, Faucet	C	1:20 PM	5	ND	Y	First Draw, Filtered.
Mitchell-81	Room 7, Community Center, Coffee Machine	PC	1:25 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested