



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Forsythe Middle School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-01	Room 112, Wood Shop, Combination Sink, Bubbler	C	8:39 AM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Forsythe-02	Room 112, Wood Shop, Combination Sink, Faucet	C	8:40 AM	5	ND	N	First Draw, Filtered.
Forsythe-03	Hallway, Outside Cafeteria, Hydration Station, Bottle Fill	BT	9:03 AM	5	ND	N	First Draw, Filtered.
Forsythe-04	Room 113, Bubbler	B	8:35 AM	5	ND	N	First Draw, Filtered.
Forsythe-05	Room 111, Bubbler	B	8:42 AM	5	ND	N	First Draw, Filtered.
Forsythe-06	Room 103, Faucet	F	9:00 AM	5	ND	Y	First Draw, Filtered.
Forsythe-07	Hallway, Outside Room 110 & Gym Annex, Hydration Station, Bottle Fill	BT	8:46 AM	5	ND	N	First Draw, Filtered.
Forsythe-08	Boys Locker Room, Hydration Station, Water Cooler	BT	8:05 AM	5	ND	N	First Draw, Filtered.
Forsythe-09	Auditorium Lobby, Single Water Cooler, Left	WC	8:29 AM	5	ND	N	First Draw, Filtered.
Forsythe-10	Kitchen, 3-Comp Sink, Add On Faucet, Far Right	KF	8:56 AM	5	ND	Y	First Draw, Filtered.
Forsythe-11	Hallway, Outside Room 110 & Gym Annex, Hydration Station, Water Cooler	BT	8:47 AM	5	ND	N	First Draw, Filtered.
Forsythe-12	Cafeteria, Combination Drinking Fountain/Glass Filler, Glass Fill Outlet	BT	8:54 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Forsythe Middle School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-13	Cafeteria, Combination Drinking Fountain/Glass Filler, Bubbler Outlet	BT	8:55 AM	5	ND	N	First Draw, Filtered.
Forsythe-14	Room 310, Right Faucet	F	9:15 AM	5	ND	Y	First Draw, Filtered.
Forsythe-15	Room 310, Left Faucet	F	9:16 AM	5	1	Y	First Draw, Filtered.
Forsythe-16	Hallway, Outside Cafeteria, Hydration Station, Water Cooler	BT	9:05 AM	5	ND	N	First Draw, Filtered.
Forsythe-17	Hallway, Inside Conference Room Wing, Faucet	F	9:07 AM	5	ND	Y	First Draw, Filtered.
Forsythe-18	Hallway, Outside Room 401, Single Water Cooler	WC	10:06 AM	5	ND	N	First Draw, Filtered.
Forsythe-19	Hallway, Outside Room 412, Single Water Cooler	WC	10:08 AM	5	ND	N	First Draw, Filtered.
Forsythe-20	Hallway, Outside Room 603, Hydration Station, Bottle Fill	BT	9:51 AM	5	ND	N	First Draw, Filtered.
Forsythe-21	Workroom, Across From Room 612, Faucet	F	9:55 AM	5	ND	Y	First Draw, Filtered.
Forsythe-22	Hallway, Outside Room 603, Hydration Station, Water Cooler	BT	9:53 AM	5	ND	N	First Draw, Filtered.
Forsythe-23	Room Across from Girls Locker Room, and Adjacent to Room 325, Ice Machine	I	9:45 AM	5	6	N	First Draw, Filtered.
Forsythe-24	Room 325, Faucet	F	9:41 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Forsythe Middle School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-25	Room 323, Faucet	F	9:38 AM	5	ND	Y	First Draw, Filtered.
Forsythe-26	Room 312, Second Island Sink Group from the Door, Left Faucet	F	9:30 AM	5	1	Y	First Draw, Filtered.
Forsythe-27	Room 312, Second Island Sink Group from the Door, Right Faucet	F	9:32 AM	5	3	Y	First Draw, Filtered.
Forsythe-28	Room 312, First Island Sink Group, Left Faucet	F	9:34 AM	5	ND	N	First Draw, Filtered.
Forsythe-29	Room 312, First Island Sink Group, Right Faucet	F	9:36 AM	5	1	N	First Draw, Filtered.
Forsythe-30	Gymnasium, Outside Girls Locker Room, Bubbler			5			Location Not Currently Functional
Forsythe-31	Gymnasium, Outside Boys Locker Room, Bubbler	B	8:00 AM	5	ND	N	First Draw, Filtered.
Forsythe-32	Girls Locker Room, Hydration Station, Bottle Fill			5			Location Not Currently Functional
Forsythe-33	Boys Locker Room, Hydration Station, Bottle Fill	BT	8:07 AM	5	ND	N	First Draw, Filtered.
Forsythe-34	Pool, Bubbler	B	8:25 AM	5	ND	N	First Draw, Filtered.
Forsythe-35	Auditorium Lobby, Hydration Station, Water Cooler	BT	8:30 AM	5	ND	N	First Draw, Filtered.
Forsythe-36	Hallway, Outside From Room 614, Single Water Cooler	WC	9:58 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Forsythe Middle School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-37	Hallway, outside From Room 501, Hydration Station, Water Cooler	BT	10:01 AM	5	ND	N	First Draw, Filtered.
Forsythe-38	Hallway, Outside From Room 501, Hydration Station, Bottle Fill	BT	10:03 AM	5	ND	N	First Draw, Filtered.
Forsythe-39	Hallway, Outside Room 113, Hydration Station, Bottle Fill			5			Location Not Currently Functional
Forsythe-40	Hallway, Outside Room 113, Hydration Station, Water Cooler	BT	7:49 AM	5	ND	N	First Draw, Filtered.
Forsythe-41	Auditorium Lobby, Hydration Station, Bottle Fill	BT	8:32 AM	5	ND	N	First Draw, Filtered.
Forsythe-42	Girls Locker Room, Hydration Station, Water Cooler			5			Location Not Currently Functional

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Forsythe Middle School							
Date of Sampling: 3/5/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-30	Gymnasium, Outside Girls Locker Room, Bubbler	B	6:45 AM	5	ND	N	First Draw, Filtered.
Forsythe-32	Girls Locker Room, Hydration Station, Bottle Fill	BT	6:50 AM	5	ND	N	First Draw, Filtered.
Forsythe-39	Hallway, Outside Room 113, Hydration Station, Bottle Fill	BT	6:55 AM	5	ND	N	First Draw, Filtered.
Forsythe-42	Girls Locker Room, Hydration Station, Water Cooler	BT	6:52 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Forsythe Middle School							
Date of Sampling: 3/4/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-23A	Room Across from Girls Locker Room, and Adjacent to Room 325, Ice Machine	I	8:23 AM	5	2	N	Sample of Upstream Piping from Ice Machine, Filtered.

Forsythe Middle School							
Date of Sampling: N/A							
Sampler: N/A							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-23	Room Across from Girls Locker Room, and Adjacent to Room 325, Ice Machine	I	N/A	5	N/A	N	Ice Machine Permanently Removed from Service Due to Lack of use

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested